E-602 Controls narrative

Coastline Tower, Suite 400 TI · 4100 Harbor Point Drive, Suite 400, Bayview, CA 92614

• Building level: shut-off by area/space controls. Demand response is not applicable (connected lighting load under 4,000 W).

• Every space: manual on/off readily accessible, multilevel switching, and occupancy sensor shut-off.

• Open Plan Office: two ceiling occupancy sensors, one per 249 ft², each controlling its zone's troffers.

• Conference Room: clerestory with interior and exterior light shelves. The whole room is the daylit zone.

DEMO REPLICA